

Good Practice for Agricultural Fuel Storage in Northern Ireland



Tanks on farms are commonly used for storing fuel oil to supply agricultural machinery and storing oil used for servicing machinery (e.g. waste lubrication and hydraulic) which can be produced in large amounts and requires containment.

Fuel oil must be stored and used safely and responsibly and be protected and contained so as to prevent pollution.



Legislation

The SSAFO (Silage, Slurry and Agricultural Fuel Oil) Regulations for Northern Ireland require any new or substantially altered agricultural fuel store with a capacity of greater than 1,250 litres to be:

- Constructed and banded to the appropriate specification; and
- Notified to NIEA (Northern Ireland Environment Agency) at least 28 days in advance of the installation being brought into use.

Bunds should be sized according to the quantity and capacity of oil storage facilities. For example, a single storage tank requires a bund capable of holding 110% of the tank capacity. Where multiple tanks are used, 110% of the largest tank or 25% of the total volume store, whichever the greater.

The Regulations allow the use of existing oil tanks to continue. However, the NIEA are empowered to inspect tanks on farms. Existing installations that are considered to present a pollution problem can be served with a notice, which requires work to be undertaken or precautions implemented to reduce the risk of pollution to watercourses or groundwater.

Design and Construction

Under the SSAFO Regulations, above ground fuel tanks and areas storing oil drums must be:

- Surrounded by an impermeable bund (if not of the integrally banded type), likely to last 20 years with proper maintenance, and sited a minimum of 10 metres away from any watercourse;
- Arranged so that any permanently fixed valves or taps empty vertically downwards into the bund and shall be shut and locked in that position when not in use;
- Fitted with an automatically closing valve or tap at the end of any flexible pipe used for filling vehicles;
- Constructed to the relevant OFTEC Standard (eg. a suitable tank to OFS T100 for plastic tanks and OFS T200 for steel tanks);
- Adequately supported on a permanent base;
- Protected from damage by vehicles;
- A visible sight glass or contents gauge and overflow alarm is recommended;
- Fitted with a shut-off valve next to the tank if it supplies a grain dryer or other fixed equipment;



- Fitted with an anti-syphon device if the tank inlet is lower than the highest level of fuel in the tank;

Tank Filling and Operating Procedures

Extra care should be taken when handling fuel oil. It is a good idea to locate sand and other absorbent materials close to storage areas for use in the event of a spillage. Detergents must never be used to clean up oil as they increase pollution risk. When not in use, valves should be closed, locked and any flexible hoses/hose outlets should be contained and locked within the bund. Also, it is important to ensure tanks, bunds and valves are regularly checked for leaks and repaired if necessary and steel tanks are adequately painted to prevent corrosion. To avoid overfilling vehicle fuel tanks, customers should arrange to be present when the fuel is delivered and a contingency plan should be put in place in case of emergency.

Emptying the Bund

Water, oil and debris accumulate within bunds over time. Therefore, to ensure bunds are able to contain any accidental spillage it is important that they are emptied regularly. A hand pump can be used to extract clean water from the sump and small amounts of oil on the surface can be removed using special oil absorbing textiles. These should then be disposed of safely. However, if contaminated water or large amounts of oil are present, a clean-up specialist must be used.

Disposing of Waste Oils

Waste oils and oily wastes should never be deposited into soakaways, waterways, drains or sewers as this can cause serious water pollution. Also, disposing



onto land poses a risk to groundwater and soil. Therefore, where waste oil cannot be reused on a farm (e.g. to fuel a heater) it should be taken to a suitable licensed waste disposal facility, usually provided by local councils.

Finding an OFTEC Registered Technician

The OFTEC website enables you to locate your nearest Registered Technicians. OFTEC Registered Technicians are appropriately qualified and insured to work on oil fired equipment.

You can also find a list of local Registered Technicians under the OFTEC logo in the 'Heating Engineers' section of your local pages.

For further information on oil heating and cooking, please see www.oftec.org

For more information on this subject or for further information sheets:

t: 0845 65 85 080 f: 0845 65 85 181 e: enquiries@oftec.org w: www.oftec.org
OFTEC Foxwood House, Dobbs Lane, Kesgrave, Ipswich IP5 2QQ